

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING NO: 3555-1588:100 Page 1 of 1

CATEGORY: Door with Integral Exit Hardware (Fire Rated)

LISTEE: Steelcraft Manufacturing Co., Div. of Ingersoll-Rand, 9017 Blue Ash Rd, Cincinnati, Oh, 45236
Contact: Jim Donlan (513) 745-6499

DESIGN: Model L Series 18 and 16 gage 1-3/4" steel doors with integral fire exit hardware devices that are inset (recessed) into the door panels. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 90 and 180 minute maximum
Nominal 1-3/4" in thickness
Positive Pressure

INSTALLATION: In accordance with listee's printed installation instruction, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, fire-rating and UL label.

APPROVAL: Listed as 90 minute and 3 hour maximum fire-rated door with integral exit hardware.
Maximum sizes listed below:

Single	4'w by 8'h
Pair	8'w by 8'h
Double Egress	8'w by 8'h

NOTE: Model L Series Double Egress doors with polystyrene core or Model L series doors over 96" net height are NOT approved for smoke and draft control openings.

03-18-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 17, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager